CE EMC
TEST REPORT

for

Adapter

MODEL: AD17XXY (XX = 03、04、05、06、07、08、09、10、11、12、13、14、15、16、17、18、19、20、22、23、24； Y = A、B、G、C、CW、CF、D、DW、DF、E、EW、F、H、HW、HF、I、IW、IF)

Test Report Number:
T120907D10-E

Issued to:

Solytech Enterprise Corporation

3F, No.18, Wu Chun 7 Rd., Wu Gu Industry Area,
Wu Gu Shiang, Taipei, Taiwan

Issued by:

Compliance Certification Services Inc.

Xindian Lab.

No.163-1, Jhongsheng Rd., Xindian Dist.,
New Taipei City, 23151 Taiwan.
TEL: 886-2-22170894

FAX: 886-2-22171029

Issued Date: September 13, 2012

Note: *This report shall not be reproduced except in full, without the written approval of Compliance Certification Services Inc. This document may be altered or revised by Compliance Certification Services Inc. personnel only, and shall be noted in the revision section of the document. The client should not use it to claim product endorsement by TAF, A2LA, NVLAP, NIST or any government agencies. The test results in the report only apply to the tested sample.*

Revision History

Rev.		Issue Date		Revisions	Effect Page	Revised By
00		July 01, 2009		Initial Issue	ALL	Joy Hsiao
01		September 13, 2012		Update Standards	ALL	Joy Hsiao

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

TABLE OF CONTENTS

1 TEST CERTIFICATION 4
2 TEST RESULT SUMMARY 5
3 EUT DESCRIPTION 6
4 TEST METHODOLOGY 7
4.1. DECISION OF FINAL TEST MODE 7
4.2. EUT SYSTEM OPERATION 7
5 SETUP OF EQUIPMENT UNDER TEST 8
5.1. DESCRIPTION OF SUPPORT UNITS 8
5.2. CONFIGURATION OF SYSTEM UNDER TEST 8
6 FACILITIES AND ACCREDITATIONS 9
6.1. FACILITIES 9
6.2. ACCREDITATIONS 9
6.3. MEASUREMENT UNCERTAINTY 9
7 EMISSION TEST 10
7.1. CONDUCTED EMISSION MEASUREMENT 10
7.2. CONDUCTED EMISSION MEASUREMENT AT TELECOMMUNICATION PORTS 14
7.3. RADIATED EMISSION MEASUREMENT 17
7.4. HARMONICS CURRENT MEASUREMENT 24
7.5. VOLTAGE FLUCTUATION AND FLICKER MEASUREMENT 27
8 IMMUNITY TEST 30
8.1. GENERAL DESCRIPTION 30
8.2. GENERAL PERFORMANCE CRITERIA DESCRIPTION 31
8.3. ELECTROSTATIC DISCHARGE (ESD) 32
8.4. RADIATED, RADIO-FREQUENCY, ELECTROMAGNETIC FIELD (RS) 36
8.5. ELECTRICAL FAST TRANSIENT (EFT) 39
8.6. SURGE IMMUNITY TEST 41
8.7. CONDUCTED RADIO FREQUENCY DISTURBANCES (CS) 43
8.8. POWER FREQUENCY MAGNETIC FIELD 46
8.9. VOLTAGE DIP & VOLTAGE INTERRUPTIONS 49
9 PHOTOGRAPHS OF THE TEST CONFIGURATION 51
APPENDIX 1 - PHOTOGRAPHS OF EUT A1-1

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

1 TEST CERTIFICATION

Product:	Adapter
Model:	AD17XXY (XX = 03、04、05、06、07、08、09、10、11、12、13、14、15、16、17、18、19、20、22、23、24； Y = A、B、G、C、CW、CF、D、DW、DF、E、EW、F、H、HW、HF、I、IW、IF)
Brand:	N/A
Applicant:	**Solytech Enterprise Corporation** 3F, No.18, Wu Chun 7 Rd., Wu Gu Industry Area, Wu Gu Shiang, Taipei, Taiwan
Manufacturer:	**Deer Electronics (DongGuan) Co., Ltd.** Chang Shan Tou, Management Area, Qing Xi, Dong Guan, Guang Dong, People's Republic of China
Tested:	June 27, 2009 ~ June 30, 2009
Applicable Standards:	**EN 55022: 2006 + A1: 2007 + A2: 2010, Class B** **EN 61000-3-2: 2006 + A1: 2009 + A2: 2009** **EN 61000-3-3: 2008** **EN 55024: 1998 + A1: 2001 + A2: 2003** IEC 61000-4-2: 2008 IEC 61000-4-3: 2006 + A1: 2007 + A2: 2010 IEC 61000-4-4: 2004 + A1: 2010 IEC 61000-4-5: 2005 IEC 61000-4-6: 2008 IEC 61000-4-8: 2009 IEC 61000-4-11: 2004

Deviation from Applicable Standard
None

The above equipment was tested by Compliance Certification Services Inc. for compliance with the requirements of technical standards specified above under the EMC Directive 2004/108/EC. The results of testing in this report apply only to the product/system, which was tested. Other similar equipment will not necessarily produce the same results due to production tolerance and measurement uncertainties

Approved by:

Jason Lee for

Sam Hu
Section Manager

Reviewed by:

Vesta Hsu.

Vesta Hsu
Supervisor of report document dept.

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

2 TEST RESULT SUMMARY

EMISSION			
Standard	**Item**	**Result**	**Remarks**
EN 55022: 2006 + A1: 2007 + A2: 2010	Conducted (Main Port)	PASS	Meet Class B limit
	Conducted (Telecom port)	N/A	Please see the page 16
	Radiated	PASS	Meet Class B limit
EN 61000-3-2: 2006 + A1: 2009 + A2: 2009	Harmonic current emissions	PASS	Meet Class A limit
EN 61000-3-3: 2008	Voltage fluctuations & flicker	PASS	Meets the requirements

IMMUNITY【 EN 55024 (1998 + A1: 2001 + A2: 2003) 】			
Standard	**Item**	**Result**	**Remarks**
IEC 61000-4-2: 2008	ESD	PASS	Meets the requirements of Performance Criterion A
IEC 61000-4-3: 2006 + A1: 2007 + A2: 2010	RS	PASS	Meets the requirements of Performance Criterion A
IEC 61000-4-4: 2004 + A1: 2010	EFT	PASS	Meets the requirements of Performance Criterion A
IEC 61000-4-5: 2005	Surge	PASS	Meets the requirements of Performance Criterion A
IEC 61000-4-6: 2008	CS	PASS	Meets the requirements of Performance Criterion A
IEC 61000-4-8: 2009	PFMF	N/A	Please see the page 48
IEC 61000-4-11: 2004	Voltage dips & voltage variations	PASS	Meets the requirements of **Voltage Dips:** 1) >95% reduction Performance Criterion A 2) 30% reduction Performance Criterion A **Voltage Interruptions:** 1) >95% reduction Performance Criterion B

Note: *1. The statements of test result on the above are decided by the request of test standard only; the measurement uncertainties are not factored into this compliance determination.*
2. The information of measurement uncertainty is available upon the customer's request.

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

3 EUT DESCRIPTION

Product	Adapter
Brand Name	N/A
Model	AD17XXY (XX = 03、04、05、06、07、08、09、10、11、12、13、14、15、16、17、18、19、20、22、23、24； Y = A、B、G、C、CW、CF、D、DW、DF、E、EW、F、H、HW、HF、I、IW、IF)
Applicant	Solytech Enterprise Corporation
Housing material	Plastic
Identify Number	90616202
Received Date	June 16, 2009
EUT Power Rating	100-240VAC, 50-60Hz
AC Power During Test	230VAC / 50Hz
DC Power Cord Type	A Type: Unshielded, 1.5m (Non-detachable) B Type: Unshielded, 1.5m (Non-detachable) D Type: Unshielded, 1.5m (Non-detachable)

MODEL DIFFERENCES

Model Name	Difference		
	Y = A、B、G、C、CW、CF、D、DW、DF、E、EW、F、H、HW、HF、I、IW、IF	**DC Output Ratings**	**Max. Wattage**
AD1703	A: Desk Top Type (2 Pin) B: Desk Top Type (3 Pin) G: Desk Top Type (3 Pin) C、CW、CF: United State's Type Plug D、DW、DF: Germany's Type Plug E、EW: United Kingdom's Type Plug F: Australia's Type Plug H、HW、HF: Korea's Type Plug I、IW、IF: China's Type Plug	3.3V / 2.6A	8.58W
AD1704		4.0V / 2.6A	10.4W
AD1705		5.0V / 2.6A	13W
AD1706		6.0V / 2.34A	14W
AD1707		7.0V / 2.0A	14W
AD1708		8.0V / 1.89A	15W
AD1709		9.0V / 1.67A	15W
AD1710		10.0V / 1.5A	15W
AD1711		11.0V / 1.37A	15W
AD1712		12.0V / 1.25A	15W
AD1713		13.0V / 1.16A	15W
AD1714		14.0V / 1.07A	15W
AD1715		15.0V / 1.0A	15W
AD1716		16.0V / 0.94A	15W
AD1717		17.0V / 0.88A	15W
AD1718		18.0V / 0.83A	15W
AD1719		19.0V / 0.79A	15W
AD1720		20.0V / 0.75A	15W
AD1722		22.0V / 0.68A	15W
AD1723		23.0V / 0.65A	15W
AD1724		24.0V / 0.63A	15W

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

I/O PORT

I/O PORT TYPES	Q'TY	TESTED WITH

Note: *Client consigns three samples to test (Model Number: AD1705A; AD1712D; AD1724B).*

4 TEST METHODOLOGY

4.1. DECISION OF FINAL TEST MODE

The EUT was tested together with the above additional components, and a configuration, which produced the worst emission levels, was selected and recorded in this report.

The test configuration/ modes are as the following:

Conduction Modes:

1.	**AD1705A**	**Full Rated Load Mode**
2.	**AD1712D**	**Full Rated Load Mode**
3.		**Half Rated Load Mode**
4.	**AD1724B**	**Full Rated Load Mode**

Radiation Modes:

1.	**AD1705A**	**Full Rated Load Mode**
2.	**AD1712D**	**Full Rated Load Mode**
3.		**Half Rated Load Mode**
4.	**AD1724B**	**Full Rated Load Mode**

Conduction: Mode 2

Radiation: Mode 2

4.2. EUT SYSTEM OPERATION

1. To adjust variable resistor to test full rating load and half rating load mode.

   Note: *Test program is self-repeating throughout the test.*

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

5 SETUP OF EQUIPMENT UNDER TEST

5.1. DESCRIPTION OF SUPPORT UNITS

The EUT has been tested as an independent unit together with other necessary accessories or support units. The following support units or accessories were used to form a representative test configuration during the tests.

Peripherals Devices:

No.	Equipment	Model No.	Serial No.	FCC ID / BSMI ID	Brand Name	Data Cable	Power Cord
1.	Variable Resistor	N/A	N/A	N/A	N/A	Unshielded, 1.5m	N/A

Note:

1) All the equipment/cables were placed in the worst-case configuration to maximize the emission during the test.

2) Grounding was established in accordance with the manufacturer's requirements and conditions for the intended use.

5.2. CONFIGURATION OF SYSTEM UNDER TEST



This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

6 FACILITIES AND ACCREDITATIONS

6.1. FACILITIES

All measurement facilities used to collect the measurement data are located at CCSrf Taiwan Xindian Lab. at No.163-1, Jhongsheng Rd., Xindian Dist., New Taipei City, 23151 Taiwan.

The sites are constructed in conformance with the requirements of ANSI C63.4 and CISPR Publication 22. All receiving equipment conforms to CISPR 16-1-1, CISPR 16-1-2, CISPR 16-1-3, CISPR 16-1-4 and CISPR 16-1-5.

6.2. ACCREDITATIONS

Our laboratories are accredited and approved by the following accreditation body according to ISO/IEC 17025.

Taiwan	TAF
USA	A2LA

The measuring facility of laboratories has been authorized or registered by the following approval agencies.

Canada	Industry Canada
Norway	Nemko
Japan	VCCI
Taiwan	BSMI
USA	FCC

Copies of granted accreditation certificates are available for downloading from our web site, http:///www.ccsrf.com

6.3. MEASUREMENT UNCERTAINTY

Where relevant, the following measurement uncertainty levels have been estimated for tests performed on the EUT as specified in CISPR 16-4-2:

Measurement	Frequency	Uncertainty
Conducted emissions	0.15MHz ~ 30MHz	± 1.7376
Radiated emissions	30MHz ~ 200MHz	± 3.8773
	200MHz ~ 1000MHz	± 3.8820

This uncertainty represents an expanded uncertainty expressed at approximately the 95% confidence level using a coverage factor of k=2.

Consistent with industry standard (e.g. CISPR 22: 2005, clause 11, Measurement Uncertainty) determining compliance with the limits shall be base on the results of the compliance measurement. Consequently the measure emissions being less than the maximum allowed emission result in this be a compliant test or passing test.

The acceptable measurement uncertainty value without requiring revision of the compliance statement is base on conducted and radiated emissions being less than U_{CISPR} which is 3.6dB and 5.2dB respectively. CCS values (called U_{Lab} in CISPR 16-4-2) is less than U_{CISPR} as shown in the table above. Therefore, MU need not be considered for compliance.

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

7 EMISSION TEST

7.1. CONDUCTED EMISSION MEASUREMENT

7.1.1. LIMITS

FREQUENCY (MHz)	Class A (dBuV)		Class B (dBuV)	
	Quasi-peak	Average	Quasi-peak	Average
0.15 - 0.5	79	66	66 - 56	56 - 46
0.50 - 5.0	73	60	56	46
5.0 - 30.0	73	60	60	50

NOTE:
(1) The lower limit shall apply at the transition frequencies.
(2) The limit decreases in line with the logarithm of the frequency in the range of 0.15 to 0.50 MHz.
(3) All emanations from a class A/B digital device or system, including any network of conductors and apparatus connected thereto, shall not exceed the level of field strengths specified above.

7.1.2. TEST INSTRUMENTS

Conducted Emission room # A				
Name of Equipment	**Manufacturer**	**Model**	**Serial Number**	**Calibration Due**
TEST RECEIVER	R&S	ESHS20	840455/006	02/12/2010
LISN (EUT)	SCHWARZBECK	NSLK 8127	8127382	12/09/2009
LISN	SOLAR	8012-50-R-24-BNC	8305114	12/09/2009
BNC CABLE	MIYAZAKI	5D-FB	BNC A4	05/11/2010
THERMO-HYGRO METER	TECPEL	DTM-303	No.7	11/24/2009
Test S/W	EMI 32.exe			

NOTE: *1. The calibration interval of the above test instruments is 12 months and the calibrations are traceable to NML/ROC and NIST/USA.*
2. N.C.R = No Calibration Request.

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

7.1.3. TEST PROCEDURES (please refer to measurement standard or CCS SOP PA-031)

Procedure of Preliminary Test

- The EUT and Support equipment, if needed, was set up as per the test configuration to simulate typical usage per the user's manual. When the EUT is a tabletop system, a wooden table with a height of 0.8 meters is used and is placed on the ground plane as per EN 55022 (see Test Facility for the dimensions of the ground plane used). When the EUT is a floor standing equipment, it is placed on the ground plane, which has a 15 cm non-conductive covering to insulate the EUT from the ground plane.
- All I/O cables were positioned to simulate typical actual usage as per EN 55022.
- The test equipment EUT installed received AC main power, through a Line Impedance Stabilization Network (LISN), which supplied power source and was grounded to the ground plane.
- All support equipment power received from a second LISN.
- The EUT test program was started. Emissions were measured on each current carrying line of the EUT using an EMI Test Receiver connected to the LISN powering the EUT.
- The Receiver scanned from 150kHz to 30MHz for emissions in each of the test modes.
- During the above scans, the emissions were maximized by cable manipulation.
- The test mode(s) described in Item 4.1 were scanned during the preliminary test.
- After the preliminary scan, we found the test mode described in Item 4.1 producing the highest emission level.
- The EUT configuration and cable configuration of the above highest emission levels were recorded for reference of the final test.

Procedure of Final Test

- EUT and support equipment were set up on the test bench as per the configuration with highest emission level in the preliminary test.
- A scan was taken on both power lines, Line 1 and Line 2, recording at least the six highest emissions. Emission frequency and amplitude were recorded into a computer in which correction factors were used to calculate the emission level and compare reading to the applicable limit.
- The test data of the worst-case condition(s) was recorded.

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

7.1.4. TEST SETUP



- For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.

7.1.5. DATA SAMPLE

Freq. (MHz)	Read Level (dBuV)	Factor (dB)	Level (dBuV)	Limit Line (dBuV)	Over Limit (dB)	Remark (P/Q/A)	Line (L1/L2)
x.xx	42.95	0.55	43.50	56	-12.50	Q	L1

Freq. = Emission frequency in MHz
Read Level = Uncorrected Analyzer/Receiver reading
Factor = Insertion loss of LISN + Cable Loss
Level = Read Level + Factor
Limit Line = Limit stated in standard
Over Limit = Reading in reference to limit
P = Peak Reading
Q = Quasi-peak Reading
A = Average Reading
L1 = Hot side
L2 = Neutral side

Calculation Formula

Over Limit (dB) = Level (dBuV) – Limit Line (dBuV)

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

7.1.6. TEST RESULTS

Model No.	AD1712D	**6dB Bandwidth**	10 KHz
Environmental Conditions	24°C, 62% RH, 1010mbar	**Test Mode**	Mode 2
Tested by	Jason Lee		

(The chart below shows the highest readings taken from the final data.)

Six Highest Conducted Emission Readings							
Frequency Range Investigated				**150 KHz to 30 MHz**			
Freq. (MHz)	Read Level (dBuV)	Factor (dB)	Level (dBuV)	Limit Line (dBuV)	Over Limit (dB)	Remark (P/Q/A)	Line (L1/L2)
0.152	**62.68**	**0.07**	**62.75**	**65.89**	**-3.14**	**Q**	**L1**
0.152	**48.13**	**0.07**	**48.20**	**55.91**	**-7.71**	**A**	**L1**
0.228	**57.65**	**0.06**	**57.71**	**62.52**	**-4.81**	**Q**	**L1**
0.228	**45.33**	**0.06**	**45.39**	**52.52**	**-7.13**	**A**	**L1**
0.312	**54.00**	**0.06**	**54.06**	**59.93**	**-5.87**	**P**	**L1**
0.312	**43.01**	**0.06**	**43.07**	**49.93**	**-6.86**	**A**	**L1**
0.155	**62.63**	**0.08**	**62.71**	**65.73**	**-3.02**	**Q**	**L2**
0.155	**49.05**	**0.08**	**49.13**	**55.74**	**-6.61**	**A**	**L2**
0.230	**57.29**	**0.07**	**57.36**	**62.45**	**-5.09**	**Q**	**L2**
0.230	**43.26**	**0.07**	**43.33**	**52.44**	**-9.11**	**A**	**L2**
0.307	**54.20**	**0.07**	**54.27**	**60.06**	**-5.79**	**P**	**L2**
0.307	**39.20**	**0.07**	**39.27**	**50.06**	**-10.79**	**A**	**L2**

NOTE: *1. L1 = Line One (Live Line) / L2 = Line Two (Neutral Line)*
2. Those frequencies only show peak emission level because that was below the Average limit, so no need to check average anymore.

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

7.2. CONDUCTED EMISSION MEASUREMENT AT TELECOMMUNICATION PORTS

7.2.1. LIMITS

For Class A Equipment

FREQUENCY (MHz)	Voltage Limit (dBuV)		Current Limit (dBuA)	
	Quasi-peak	Average	Quasi-peak	Average
0.15 ~ 0.5	97 ~ 87	84 ~ 74	53 ~ 43	40 ~ 30
0.5 ~ 30.0	87	74	43	30

NOTE: *The limits decrease linearly with the logarithm of the frequency in the range 0.15 MHz to 0.5 MHz.*

For Class B Equipment

FREQUENCY (MHz)	Voltage Limit (dBuV)		Current Limit (dBuA)	
	Quasi-peak	Average	Quasi-peak	Average
0.15 - 0.5	84 ~ 74	74 ~ 64	40 ~ 30	30 ~ 20
0.5 - 30.0	74	64	30	20

NOTE: *The limits decrease linearly with the logarithm of the frequency in the range 0.15 MHz to 0.5 MHz.*

7.2.2. TEST INSTRUMENTS

Conducted Emission room #				
Name of Equipment	Manufacturer	Model	Serial Number	Calibration Due

NOTE: *1. The calibration interval of the above test instruments is 12 months and the calibrations are traceable to NML/ROC and NIST/USA.*
2. N.C.R = No Calibration Request.

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

7.2.3. TEST PROCEDURE (please refer to measurement standard or CCS SOP PA-031)

- Selecting ISN for unscreened cable or a current probe for screened cable to take measurement.
- The port of the EUT was connected to the remote side support equipment through the ISN/Current Probe and communication in normal condition.
- Making a overall range scan by using the test receiver controlled by controller and record at least six highest emissions for showing in the test report.
- Emission frequency and amplitude were recorded into a computer in which correction factors were used to calculate the emission level and compare reading to the applicable limit.
- In case of measuring on the screened cable, the current limit shall be applied; otherwise the voltage limit should be applied.
- The following test mode was scanned during the preliminary test:

  N/A

- After the preliminary scan, we found the following test mode(s) producing the highest emission level and test data of the worst case was recorded.

  N/A

7.2.4. TEST SETUP



- For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

7.2.5. DATA SAMPLE

Freq. (MHz)	Read Level (dBuV)	Factor (dB)	Level (dBuV)	Limit Line (dBuV)	Over Limit (dB)	Remark (P/Q/A)
x.xx	62.95	0.55	63.50	84	-20.50	Q

Freq. = Emission frequency in MHz
Read Level = Uncorrected Analyzer/Receiver reading
Factor = Insertion loss of ISN + Cable Loss
Level = Read Level + Factor
Limit = Limit stated in standard
Over Limit = Reading in reference to limit
P = Peak Reading
Q = Quasi-peak Reading
A = Average Reading

Calculation Formula

Over Limit (dB) = Level (dBuV) – Limit (dBuV)

7.2.6. TEST RESULTS

Model No.	N/A	**6dB Bandwidth**	N/A
Environmental Conditions	N/A	**Test Mode**	N/A
Tested by	N/A		

NOTE: *No applicable, the EUT doesn't have LAN Port or Modem port.*

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

7.3. RADIATED EMISSION MEASUREMENT

7.3.1. LIMITS

Below 1GHz

FREQUENCY (MHz)	dBuV/m (At 10m)	
	Class A	Class B
30 ~ 230	40	30
230 ~ 1000	47	37

Above 1GHz

Frequency (MHz)	Class A (dBuV/m) (At 3m)		Class B (dBuV/m) (At 3m)	
	Average	Peak	Average	Peak
1000 ~ 3000	56	76	50	70
3000 ~ 6000	60	80	54	74

NOTE: The lower limit shall apply at the transition frequencies.

According to EN 55022: 2010 clause 6.2, the measurement frequency range shown in the following table:

Highest frequency generated or used within the EUT or on which the EUT operates or tunes (MHz)	Upper frequency of measurement range (MHz)
Less than 108	1000
108-500	2000
500-1000	5000
Above 1000	5 times of the highest frequency or 6GHz, whichever is less

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

7.3.2. TEST INSTRUMENTS

Open Area Test Site # J				
Name of Equipment	**Manufacturer**	**Model**	**Serial Number**	**Calibration Due**
MEASURE RECEIVER	SCHAFFNER	SCR3501	330	06/09/2010
SPECTRUM ANALYZER	ADVANTEST	R3132	120900002	No Calibration Required
ANTENNA	SCHAFFNER	CBL 6112B	2800	09/09/2009
PRE-AMPLIFIER	SCHAFFNER	CPA9231A	3613	06/03/2010
CABLE	BELDEN	9913	N-TYPE #J3	01/22/2010
THERMO-HYGRO METER	TECPEL	DTM-303	NO.3	11/24/2009
Test S/W	EZ-EMC			
Above 1GHz Used				
Spectrum Analyzer	Agilnet	E4407B	MY44212679	12/28/2009
Pre-Amplifier	HP	8449B	3008A00965	12/31/2009
Pre-Amplifier	MITEQ	AMF-6F-260400-40-8P	985646	05/24/2010
Horn Antenna	EMCO	3115	9602-4659	04/16/2010
Horn Antenna	EMCO	3116	00026370	10/15/2009
Site VSWR	SIDT EUROPE	9x6x6	N/A	02/27/2010
Turn Table	CCS	CC-T-1F	N/A	N.C.R
Antenna Tower	CCS	CC-A-1F	N/A	N.C.R
Controller	CCS	CC-C-1F	N/A	N.C.R
Test S/W	CCS-3A1RE			

NOTE: *1. The calibration interval of the above test instruments is 12 months and the calibrations are traceable to NML/ROC and NIST/USA.*

2. N.C.R = No Calibration Request.

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

7.3.3. TEST PROCEDURE (please refer to measurement standard or CCS SOP PA-031)

Procedure of Preliminary Test

- The equipment was set up as per the test configuration to simulate typical usage per the user's manual. When the EUT is a tabletop system, a wooden turntable with a height of 0.8 meters is used which is placed on the ground plane. When the EUT is a floor standing equipment, it is placed on the ground plane which has a 15 cm non-conductive covering to insulate the EUT from the ground plane.
- Support equipment, if needed, was placed as per EN 55022.
- All I/O cables were positioned to simulate typical usage as per EN 55022.
- The EUT received AC power source from the outlet socket under the turntable. All support equipment power received from another socket under the turntable.
- The antenna was placed at 3 or 10 meter away from the EUT as stated in EN 55022. The antenna connected to the Spectrum Analyzer via a cable and at times a pre-amplifier would be used.
- The Analyzer / Receiver quickly scanned from 30MHz to 6000MHz. The EUT test program was started. Emissions were scanned and measured rotating the EUT to 360 degrees and positioning the antenna 1 to 4 meters above the ground plane, in both the vertical and the horizontal polarization, to maximize the emission reading level.
- The test mode(s) described in Item 4.1 were scanned during the preliminary test:
- After the preliminary scan, we found the test mode described in Item 4.1 producing the highest emission level.
- The EUT and cable configuration, antenna position, polarization and turntable position of the above highest emission level were recorded for the final test.

Procedure of Final Test

- EUT and support equipment were set up on the turntable as per the configuration with highest emission level in the preliminary test.
- The Analyzer / Receiver scanned from 30MHz to 6000MHz. Emissions were scanned and measured rotating the EUT to 360 degrees, varying cable placement and positioning the antenna 1 to 4 meters above the ground plane, in both the vertical and the horizontal polarization, to maximize the emission reading level.
- Recorded at least the six highest emissions. Emission frequency, amplitude, antenna position, polarization and turntable position were recorded into a computer in which correction factors were used to calculate the emission level and compare reading to the applicable limit. Below 1GHz the Q.P. reading and above 1GHz the Peak and Average reading are presented.
- The test data of the worst-case condition(s) was recorded.

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

7.3.4. TEST SETUP

Below 1GHz



Above 1GHz



- For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

7.3.5. DATA SAMPLE

Below 1GHz

Freq. (MHz)	Reading (dBuV/m)	Factor (dB)	Result (dBuV/m)	Limit (dBuV/m)	Margin (dB)	Detector (P/Q)	Pol. (H/V)
x.xx	14.0	12.2	26.2	30	-3.8	Q	H

Freq. = Emission frequency in MHz
Reading = Uncorrected Analyzer/Receiver reading
Factor = Antenna Factor + Cable Loss + Attenuator (3/6/10dB) – Amplifier Gain
Result = Uncorrected Analyzer/Receiver reading + Factor
Limit = Limit stated in standard
Margin = Reading in reference to limit
P = Peak Reading
Q = Quasi-peak Reading
H = Antenna Polarization: Horizontal
V = Antenna Polarization: Vertical

Calculation Formula

Margin (dB) = Level (dBuV/m) – Limit (dBuV/m)

Above 1GHz

Freq. (MHz)	Reading (dBuV/m)	Factor (dB)	Result (dBuV/m)	Limit (dBuV/m)	Margin (dB)	Detector (P/A)	Pol. (H/V)
x.xx	42.95	0.55	43.50	54	-10.50	A	H

Freq. = Emission frequency in MHz
Reading = Uncorrected Analyzer/Receiver reading
Factor = Antenna Factor + Cable Loss - Amplifier Gain
Result = Reading + Factor
Limit = Limit stated in standard
Margin = Result – Limit
P = Peak Reading
A = Average Reading
H = Antenna Polarization: Horizontal
V = Antenna Polarization: Vertical

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

7.3.6. TEST RESULTS

Below 1GHz

Model No.	AD1712D	**Test Mode**	Mode 2
Environmental Conditions	26°C, 78% RH, 1010mbar	**6dB Bandwidth**	120 KHz
Antenna Pole	Vertical / Horizontal	**Antenna Distance**	10m
Detector Function	Quasi-peak.	**Tested by**	Jason Lee

(The chart below shows the highest readings taken from the final data.)

Six Highest Radiated Emission Readings							
Frequency Range Investigated				**30 MHz to 1000 MHz at 10m**			
Freq. (MHz)	Reading (dBuV/m)	Factor (dB)	Result (dBuV/m)	Limit (dBuV/m)	Margin (dB)	Detector (P/Q)	Pol. (H/V)
47.6500	**43.80**	**-18.00**	**25.80**	**30.00**	**-4.20**	**Q**	**V**
55.2300	**44.20**	**-20.77**	**23.43**	**30.00**	**-6.57**	**Q**	**V**
67.2800	**40.80**	**-21.65**	**19.15**	**30.00**	**-10.85**	**Q**	**V**
85.3300	**42.90**	**-19.93**	**22.97**	**30.00**	**-7.03**	**Q**	**V**
116.8700	**39.70**	**-16.02**	**23.68**	**30.00**	**-6.32**	**Q**	**V**
120.2400	**40.20**	**-15.85**	**24.35**	**30.00**	**-5.65**	**Q**	**V**

(The chart below shows the highest readings taken from the final data.)

Six Highest Radiated Emission Readings							
Frequency Range Investigated				**30 MHz to 1000 MHz at 10m**			
Freq. (MHz)	Reading (dBuV/m)	Factor (dB)	Result (dBuV/m)	Limit (dBuV/m)	Margin (dB)	Detector (P/Q)	Pol. (H/V)
46.8800	**40.50**	**-17.53**	**22.97**	**30.00**	**-7.03**	**Q**	**H**
56.2700	**40.10**	**-21.04**	**19.06**	**30.00**	**-10.94**	**Q**	**H**
68.5300	**39.70**	**-21.59**	**18.11**	**30.00**	**-11.89**	**Q**	**H**
83.2700	**38.60**	**-20.19**	**18.41**	**30.00**	**-11.59**	**Q**	**H**
115.3400	**38.20**	**-16.10**	**22.10**	**30.00**	**-7.90**	**Q**	**H**
119.6300	**38.60**	**-15.87**	**22.73**	**30.00**	**-7.27**	**Q**	**H**

NOTE: *1. P= Peak Reading; Q= Quasi-peak Reading.*
2. The other emission levels were very low against the limit.

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

Above 1GHz

Model No.	N/A	**Test Mode**	N/A
Environmental Conditions	N/A	**6dB Bandwidth**	N/A
Antenna Pole	65kHz	**Antenna Distance**	N/A
Detector Function	N/A	**Tested by**	N/A

NOTE: *No applicable, when the highest frequency of the internal sources of the EUT is less than 108MHz, the measurement shall only be made up to 1 GHz.*

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

7.4. HARMONICS CURRENT MEASUREMENT

7.4.1. LIMITS OF HARMONICS CURRENT MEASUREMENT

Limits for Class A equipment	
Harmonics Order n	Max. permissible harmonics current A
Odd harmonics	
3	2.30
5	1.14
7	0.77
9	0.40
11	0.33
13	0.21
15<=n<=39	0.15x15/n
Even harmonics	
2	1.08
4	0.43
6	0.30
8<=n<=40	0.23x8/n

Limits for Class D equipment		
Harmonics Order n	Max. permissible harmonics current per watt mA/W	Max. permissible harmonics current A
Odd Harmonics only		
3	3.4	2.30
5	1.9	1.14
7	1.0	0.77
9	0.5	0.40
11	0.35	0.33
13	0.30	0.21
15<=n<=39	3.85/n	0.15x15/n

NOTE: *1. Class A and Class D are classified according to item 7.4.3.*

2. According to section 7 of EN 61000-3-2, the above limits for all equipment except for lighting equipment having an active input power > 75 W and no limits apply for equipment with an active input power up to and including 75 W.

7.4.2. TEST INSTRUMENTS

Name of Equipment	Manufacturer	Model	Serial Number	Calibration Due
Signal Conditioning Unit	Schaffner	CCN 1000-1	72122	11/23/2009
5KVA AC Power Source	Schaffner	NSG 1007	55131	11/23/2009
Software	Win2100V3.exe			

NOTE: *The calibration interval of the above test instruments is 12 months and the calibrations are traceable to NML/ROC and NIST/USA.*

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

7.4.3. TEST PROCEDURE (please refer to measurement standard or CCS SOP PA-029)

- The EUT was placed on the top of a wooden table 0.8 meters above the ground and operated to produce the maximum harmonic components under normal operating conditions for each successive harmonic component in turn.
- The classification of EUT is according to section 5 of EN 61000-3-2.
- The EUT is classified as follows:

  Class A: Balanced three-phase equipment, Household appliances excluding equipment as Class D, Tools excluding portable tools, Dimmers for incandescent lamps, audio equipment, equipment not specified in one of the three other classes.

  Class B: Portable tools; Arc welding equipment which is not professional equipment.

  Class C: Lighting equipment.

  Class D: Equipment having a specified power less than or equal to 600 W of the following types: Personal computers and personal computer monitors and television receivers.

- The correspondent test program of test instrument to measure the current harmonics emanated from EUT is chosen. The measure time shall be not less than the time necessary for the EUT to be exercised.

7.4.4. TEST SETUP



- For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.

7.4.5. TEST RESULTS

Power Consumption	19.1W	**Test Mode**	Operating
Environmental Conditions	18°C, 58% RH, 1008mbar	**Tested by**	Webber Chung

NOTE: *1. Limits classified according to item 7.4.1.*
2. According to clause 7 of EN 61000-3-2, equipment with a rated power of 75W or less, no limits apply. The test result is only for reference.

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

TEST RESULT OF EN 61000-3-2

Highest parameter values during test:

V_RMS (Volts):	**230.09**	**Frequency(Hz):**	**50.00**
I_Peak (Amps):	**1.095**	**I_RMS (Amps):**	**0.204**
I_Fund (Amps):	**0.086**	**Crest Factor:**	**10.342**
Power (Watts):	**19.1**	**Power Factor:**	**0.408**

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

7.5. VOLTAGE FLUCTUATION AND FLICKER MEASUREMENT

7.5.1. LIMITS OF VOLTAGE FLUCTUATION AND FLICKER MEASUREMENT

TEST ITEM	LIMIT	REMARK
P_{st}	1.0	P_{st} means short-term flicker indicator.
P_{lt}	0.65	P_{lt} means long-term flicker indicator.
T_{dt} (ms)	500	T_{dt} means maximum time that dt exceeds 3 %.
d_{max} (%)	4%	d_{max} means maximum relative voltage change.
dc (%)	3.3%	dc means relative steady-state voltage change

7.5.2. TEST INSTRUMENTS

IMMUNITY SHIELDED ROOM				
Name of Equipment	**Manufacturer**	**Model**	**Serial Number**	**Calibration Due**
Signal Conditioning Unit	Schaffner	CCN 1000-1	72122	11/23/2009
5KVA AC Power Source	Schaffner	NSG 1007	55131	11/23/2009
Software	Win2100V3.exe			

NOTE: *The calibration interval of the above test instruments is 12 months and the calibrations are traceable to NML/ROC and NIST/USA.*

7.5.3. TEST PROCEDURE (please refer to measurement standard or CCS SOP PA-030)

- The EUT was placed on the top of a wooden table 0.8 meters above the ground and operated to produce the most unfavorable sequence of voltage changes under normal operating conditions.
- During the flick measurement, the measure time shall include that part of whole operation cycle in which the EUT produce the most unfavorable sequence of voltage changes. The observation period for short-term flicker indicator is 10 minutes and the observation period for long-term flicker indicator is 2 hours.

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

7.5.4. TEST SETUP



- For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.

7.5.5. TEST RESULTS

Observation Period (Tp)	10mins	**Test Mode**	Operating
Environmental Conditions	18°C, 58% RH, 1008mbar	**Tested by**	Webber Chung

TEST PARAMETER	MEASUREMENT VALUE	LIMIT	REMARK
P_{st}	0.064	1.0	PASS
P_{lt}	0.040	0.65	PASS
T_{dt} (ms)	0	500	PASS
d_{max} (%)	-0.07	4%	PASS
dc (%)	0	3.3%	PASS

Note: *None.*

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

TEST RESULT OF EN 61000-3-3

Test Result: Pass **Status: Test Completed**

Pst_i and limit line **European Limits**

Plt and limit line



Parameter values recorded during the test:

Vrms at the end of test (Volt):	**230.05**			
Highest dt (%):	**-0.13**	**Test limit (%):**	**3.14**	**Pass**
Time(mS) > dt:	**0.0**	**Test limit (mS):**	**500.0**	**Pass**
Highest dc (%):	**0.00**	**Test limit (%):**	**3.14**	**Pass**
Highest dmax (%):	**-0.07**	**Test limit (%):**	**3.80**	**Pass**
Highest Pst (10 min. period):	**0.064**	**Test limit:**	**0.950**	**Pass**
Highest Plt (2 hr. period):	**0.040**	**Test limit:**	**0.617**	**Pass**

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

8 IMMUNITY TEST

8.1. GENERAL DESCRIPTION

Product Standard	EN 55024: 1998 + A1: 2001 + A2: 2003	
	Test Type	**Minimum Requirement**
Basic Standard, Specification, and Performance Criterion required	IEC 61000-4-2	Electrostatic Discharge – ESD: 8KV air discharge, 4KV Contact discharge, Performance Criterion B
	IEC 61000-4-3	Radio-Frequency Electromagnetic Field Susceptibility Test – RS: 80 ~1000 MHz, 3V/m, 80% AM(1kHz), Performance Criterion A
	IEC 61000-4-4	Electrical Fast Transient/Burst - EFT, Power line: 1KV, Signal line: 0.5KV, Performance Criterion B
	IEC 61000-4-5	Surge Immunity Test: 1.2/50 μs Open Circuit Voltage, 8 /20 μs Short Circuit Current, Power Port ~ Line to line: 1KV, Line to ground: 2KV Signal Port ~ Lines to ground: 1KV Performance Criterion B
	IEC 61000-4-6	Conducted Radio Frequency Disturbances Test – CS: 0.15 ~ 80 MHz, 3Vrms, 80% AM, 1kHz, Performance Criterion A
	IEC 61000-4-8	Power frequency magnetic field immunity test 50 Hz, 1A/m Performance Criterion A
	IEC 61000-4-11	Voltage Dips: i) >95% reduction for 0.5 period, Performance Criterion B ii) 30% reduction for 25 period, Performance Criterion C Voltage Interruptions: >95% reduction for 250 period Performance Criterion C

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

8.2. GENERAL PERFORMANCE CRITERIA DESCRIPTION

Criteria A:	The apparatus shell continues to operate as intended without operator intervention. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended. The performance level may be replaced by a permissible loss of performance. If the manufacturer does not specify the minimum performance level or the permissible performance loss, then either of these may be derived from the product description and documentation, and by what the user may reasonably expect from the equipment if used as intended.
Criteria B:	After test, the apparatus shell continues to operate as intended without operator intervention. No degradation of performance or loss of function is allowed, after the application of the phenomenon below a performance level specified by the manufacturer, when the apparatus is used as intended. The performance level may be replaced by a permissible loss of performance. During the test, degradation of performance is however allowed. However, no change of operating state if stored data is allowed to persist after the test. If the manufacturer does not specify the minimum performance level or the permissible performance loss, then either of these may be derived from the product description and documentation, and by what the user may reasonably expect from the equipment if used as intended.
Criteria C:	Temporary loss of function is allowed, provided the functions is self-recoverable or can be restored by the operation of controls by the user in accordance with the manufacturer instructions. Functions, and/or information stored in non-volatile memory, or protected by a battery backup, shall not be lost.

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

8.3. ELECTROSTATIC DISCHARGE (ESD)

8.3.1. TEST SPECIFICATION

Basic Standard:	EN 61000-4-2
Discharge Impedance:	330 ohm / 150 pF
Discharge Voltage:	Air Discharge: 2 ; 4 ; 8 KV (Direct) Contact Discharge: 2 ; 4 KV (Direct/Indirect)
Polarity:	Positive & Negative
Number of Discharge:	Minimum 10 times at each test point
Discharge Mode:	Single Discharge 1 second minimum

8.3.2. TEST INSTRUMENT

IMMUNITY SHIELDED ROOM				
Name of Equipment	**Manufacturer**	**Model**	**Serial Number**	**Calibration Due**
ESD Simulator	Schaffner	NSG 438	170	08/21/2009
Aneroid Barometer	Sato	7610-20	89090	11/30/2009
Thermo-Hygro meter	TECPEL	DTM-303	No.7	11/24/2009

NOTE: *The calibration interval of the above test instruments is 12 months and the calibrations are traceable to NML/ROC and NIST/USA.*

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

8.3.3. TEST PROCEDURE (please refer to measurement standard or CCS SOP PA-022)

The discharges shall be applied in two ways:

a) Contact discharges to the conductive surfaces and coupling planes:
   The EUT shall be exposed to at least 200 discharges, 100 each at negative and positive polarity, at a minimum of four test points. One of the test points shall be subjected to at least 50 indirect discharges to the center of the front edge of the **H**orizontal **C**oupling **P**lane (**HCP**). The remaining three test points shall each receive at least 50 direct contact discharges. If no direct contact test points are available, then at least 200 indirect discharges shall be applied in the indirect mode. Test shall be performed at a maximum repetition rate of one discharge per second.

b) Air discharges at slots and apertures and insulating surfaces:
   On those parts of the EUT where it is not possible to perform contact discharge testing, the equipment should be investigated to identify user accessible points where breakdown may occur. Such points are tested using the air discharge method. This investigation should be restricted to those area normally handled by the user. A minimum of 10 single air discharges shall be applied to the selected test point for each such area.

The basic test procedure was in accordance with IEC 61000-4-2:

a) The EUT was located 0.1 m minimum from all side of the **HCP** (dimensions 1.6m x 0.8m).
b) The support units were located another table 30 cm away from the EUT, but direct support unit was/were located at same location as EUT on the HCP and keep at a distance of 10 cm with EUT.
c) The time interval between two successive single discharges was at least 1 second.
d) Contact discharges were applied to the non-insulating coating, with the pointed tip of the generator penetrating the coating and contacting the conducting substrate.
e) Air discharges were applied with the round discharge tip of the discharge electrode approaching the EUT as fast as possible (without causing mechanical damage) to touch the EUT. After each discharge, the ESD generator was removed from the EUT and re-triggered for a new single discharge. The test was repeated until all discharges were complete.
f) At least ten single discharges (in the most sensitive polarity) were applied at the front edge of each **HCP** opposite the center point of each unit of the EUT and 0.1 meters from the front of the EUT. The long axis of the discharge electrode was in the plane of the **HCP** and perpendicular to its front edge during the discharge.
g) At least ten single discharges (in the most sensitive polarity) were applied to the center of one vertical edge of the **V**ertical **C**oupling **P**lane (**VCP**) in sufficiently different positions that the four faces of the EUT were completely illuminated. The **VCP** (dimensions 0.5m x 0.5m) was placed vertically to and 0.1 meters from the EUT.

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

8.3.4. TEST SETUP



Ground Reference Plane

- For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.

NOTE:

TABLE-TOP EQUIPMENT

The configuration consisted of a wooden table 0.8 meters high standing on the **G**round **R**eference **P**lane. The **GRP** consisted of a sheet of aluminum at least 0.25mm thick, and 2.5 meters square connected to the protective grounding system. A **H**orizontal **C**oupling **P**lane (1.6m x 0.8m) was placed on the table and attached to the **GRP** by means of a cable with 940k Ω total impedance. The equipment under test, was installed in a representative system as described in section 7 of EN 61000-4-2, and its cables were placed on the **HCP** and isolated by an insulating support of 0.5mm thickness. A distance of 1-meter minimum was provided between the EUT and the walls of the laboratory and any other metallic structure.

FLOOR-STANDING EQUIPMENT

The equipment under test was installed in a representative system as described in section 7 of IEC 61000-4-2, and its cables were isolated from the Ground Reference Plane by an insulating support of 0.1-meter thickness. The GRP consisted of a sheet of aluminum that is at least 0.25mm thick, and 2.5 meters square connected to the protective grounding system and extended at least 0.5 meters from the EUT on all sides.

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

8.3.5. TEST RESULTS

Temperature	18°C	**Humidity**	58% RH
Pressure	1008mbar	**Tested By**	David Cheng
Required Passing Performance		**Criterion B**	

Air Discharge								
Test Points	**Test Levels**			**Results**				
	± 2 KV	**± 4 KV**	**± 8 KV**	**Pass**	**Fail**	**Performance Criterion**	**Observation**	
Front	☒	☒	☒	☒	☐	☒**A** ☐**B**	**Note** ☐**1**	☒**2**
Back	☒	☒	☒	☒	☐	☒**A** ☐**B**	**Note** ☐**1**	☒**2**
Left	☒	☒	☒	☒	☐	☒**A** ☐**B**	**Note** ☐**1**	☒**2**
Right	☒	☒	☒	☒	☐	☒**A** ☐**B**	**Note** ☐**1**	☒**2**
Top	☒	☒	☒	☒	☐	☒**A** ☐**B**	**Note** ☐**1**	☒**2**
Bottom	☒	☒	☒	☒	☐	☒**A** ☐**B**	**Note** ☐**1**	☒**2**

Please refer to ESD test photo on next page for detail discharge point

Discharge To Horizontal Coupling Plane								
Side of EUT	**Test Levels**			**Results**				
	± 2 KV	**± 4 KV**	**± 8 KV**	**Pass**	**Fail**	**Performance Criterion**	**Observation**	
Front	☒	☒	☐	☒	☐	☒**A** ☐**B**	**Note** ☒**1**	☐**2**
Back	☒	☒	☐	☒	☐	☒**A** ☐**B**	**Note** ☒**1**	☐**2**
Left	☒	☒	☐	☒	☐	☒**A** ☐**B**	**Note** ☒**1**	☐**2**
Right	☒	☒	☐	☒	☐	☒**A** ☐**B**	**Note** ☒**1**	☐**2**

Discharge To Vertical Coupling Plane								
Side of EUT	**Test Levels**			**Results**				
	± 2 KV	**± 4 KV**	**± 8 KV**	**Pass**	**Fail**	**Performance Criterion**	**Observation**	
Front	☒	☒	☐	☒	☐	☒**A** ☐**B**	**Note** ☒**1**	☐**2**
Back	☒	☒	☐	☒	☐	☒**A** ☐**B**	**Note** ☒**1**	☐**2**
Left	☒	☒	☐	☒	☐	☒**A** ☐**B**	**Note** ☒**1**	☐**2**
Right	☒	☒	☐	☒	☐	☒**A** ☐**B**	**Note** ☒**1**	☐**2**

NOTE: *1. There was no change compared with initial operation during the test.*
2. No discharge point.

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

8.4. RADIATED, RADIO-FREQUENCY, ELECTROMAGNETIC FIELD (RS)

8.4.1. TEST SPECIFICATION

Basic Standard:	EN 61000-4-3
Frequency Range:	80 MHz ~1000 MHz
Field Strength:	3 V/m
Modulation:	1kHz Sine Wave, 80%, AM Modulation
Frequency Step:	1 % of preceding frequency value
Polarity of Antenna:	Horizontal and Vertical
Test Distance:	3 m
Antenna Height:	1.5 m

8.4.2. TEST INSTRUMENT

733 RS Chamber				
Name of Equipment	**Manufacturer**	**Model**	**Serial Number**	**Calibration Due**
Calibration of Field	N/A	Chamber#RS	Ver(Hor)-200805	06/16/2010
Signal Generator	Agilent	E4421B	MY43350597	05/21/2010
Electric Field Probe	AR	FP6001	305650	06/02/2010
RF Power Meter	Boonton	4231A	39601	08/11/2009
Amplifier	AR	100W1000M1	17564	No Calibration Required
Direction Coupler	AR	DC6180A	312189	No Calibration Required
Broadband Antenna	AR	AT1080	311819	No Calibration Required
Thermo-Hygro meter	TFA	N/A	NO.6	11/10/2009
Software	SW1005 Relrase 1.4.exe			

NOTE: *1. The calibration interval of the above test instruments is 12 months and the calibrations are traceable to NML/ROC and NIST/USA.*
2. N.C.R.= No Calibration required

8.4.3. TEST PROCEDURE (please refer to measurement standard or CCS SOP PA-023)

The test procedure was in accordance with EN 61000-4-3

a) The testing was performed in a fully anechoic chamber. The transmit antenna was located at a distance of 3 meters from the EUT.

b) The frequency range is swept from 80 MHz to 1000 MHz, with the signal 80% amplitude modulated with a 1kHz sine-wave. The rate of sweep did not exceed 1.5 x 10^{-3} decade/s, where the frequency range is swept incrementally, the step size was 1% of preceding frequency value.

c) The dwell time at each frequency shall be not less than the time necessary for the EUT to be able to respond.

e) The test was performed with the EUT exposed to both vertically and horizontally polarized fields on each of the four sides.

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

8.4.4. TEST SETUP



- For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.

NOTE:

TABLETOP EQUIPMENT

The EUT installed in a representative system as described in section 7 of EN 61000-4-3 was placed on a non-conductive table 0.8 meters in height. The system under test was connected to the power and signal wire according to relevant installation instructions.

FLOOR STANDING EQUIPMENT

The EUT installed in a representative system as described in section 7 of IEC 61000-4-3 was placed on a non-conductive wood support 0.1 meters in height. The system under test was connected to the power and signal wire according to relevant installation instructions.

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

8.4.5. TEST RESULTS

Temperature	18°C	**Humidity**	58% RH
Pressure	1008mbar	**Dwell Time**	3 sec.
Tested By	David Cheng	**Required Passing Performance**	**Criterion A**

Frequency (MHz)	Polarity	Azimuth	Field Strength (V/m)	Observation	Result
80 ~ 1000	V&H	0	3	Note	PASS
80 ~ 1000	V&H	90	3	Note	PASS
80 ~ 1000	V&H	180	3	Note	PASS
80 ~ 1000	V&H	270	3	Note	PASS

NOTE: *There was no change compared with the initial operation during the test.*

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

8.5. ELECTRICAL FAST TRANSIENT (EFT)

8.5.1. TEST SPECIFICATION

Basic Standard:	EN 61000-4-4
Test Voltage:	Power Line: 1 KV
Polarity:	Positive & Negative
Impulse Frequency:	5 kHz
Impulse Wave-shape:	5/50 ns
Burst Duration:	15 ms
Burst Period:	300 ms
Test Duration:	Not less than 1 min.

8.5.2. TEST INSTRUMENT

Immunity Shield Room				
Name of Equipment	**Manufacturer**	**Model**	**Serial Number**	**Calibration Due**
EFT Generator	Schaffner	BEST EMC V2.3	200031A024SC	11/09/2009
Capacitive Clamp	EMC-Partner	CN-EFT1000	589	No Calibration Required
Software	WinBest.exe			

NOTE: *1. The calibration interval of the above test instruments is 12 months and the calibrations are traceable to NML/ROC and NIST/USA.*
2. N.C.R.= No Calibration required

8.5.3. TEST PROCEDURE (please refer to measurement standard or CCS SOP PA-024)

a) Both positive and negative polarity discharges were applied.

b) The length of the " hot wire " from the coaxial output of the EFT generator to the terminals on the EUT should not exceed 0.5 meter.

c) The duration time of each test sequential was 1 minute.

d) The transient/burst waveform was in accordance with EN 61000-4-4, 5/50ns.

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

8.5.4. TEST SETUP



- For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.

NOTE:

TABLETOP EQUIPMENT

The configuration consisted of a wooden table (0.1m high) standing on the Ground Reference Plane. The GRP consisted of a sheet of aluminum (at least 0.25mm thick and 2.5m square) connected to the protective grounding system. A minimum distance of 0.5m was provided between the EUT and the walls of the laboratory or any other metallic structure.

FLOOR STANDING EQUIPMENT

The EUT installed in a representative system as described in section 7 of IEC 61000-4-4 and its cables, were isolated from the Ground Reference Plane by an insulating support that is 0.1-meter thick. The GRP consisted of a sheet of aluminum (at least 0.25mm thick and 2.5m square) connected to the protective grounding system.

8.5.5. TEST RESULTS

Temperature	18°C	**Humidity**	58% RH
Pressure	1008mbar	**Tested By**	David Cheng
Required Passing Performance		**Criterion B**	

Test Point	Polarity	Test Level (KV)	Performance Criterion	Observation	Result
L	+/-	1	☒A ☐B	Note ☒1 ☐2	PASS
N	+/-	1	☒A ☐B	Note ☒1 ☐2	PASS
L – N	+/-	1	☒A ☐B	Note ☒1 ☐2	PASS

NOTE: *1. There was no change compared with initial operation during the test.*

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

8.6. SURGE IMMUNITY TEST

8.6.1. TEST SPECIFICATION

Basic Standard:	EN 61000-4-5
Wave-Shape:	Combination Wave 1.2/50 us Open Circuit Voltage 8/20 us Short Circuit Current
Test Voltage:	Power Line ~ Line to Line: 1 KV
Surge Input/Output:	Power Line: L-N
Generator Source Impedance:	2 ohm between networks 12 ohm between network and ground
Polarity:	Positive/Negative
Phase Angle:	0° / 90° / 180° / 270°
Pulse Repetition Rate:	1 time / min. (maximum)
Number of Tests:	5 positive and 5 negative at selected points

8.6.2. TEST INSTRUMENT

Immunity Shield Room				
Name of Equipment	**Manufacturer**	**Model**	**Serial Number**	**Calibration Due**
Surger Generator	Schaffner	BEST EMC V2.3	200031A024SC	11/09/2009
Signal and Data Lines Coupling Network	Schaffner	CDN118	19328	No Calibration Required
Software	WinBest.exe			

NOTE: *1. The calibration interval of the above test instruments is 12 months and the calibrations are traceable to NML/ROC and NIST/USA.*
2. N.C.R.= No Calibration required

8.6.3. TEST PROCEDURE (please refer to measurement standard or CCS SOP PA-025)

a) For EUT power supply:

The surge is applied to the EUT power supply terminals via the capacitive coupling network. Decoupling networks are required in order to avoid possible adverse effects on equipment not under test that may be powered by the same lines, and to provide sufficient decoupling impedance to the surge wave. The power cord between the EUT and the coupling/decoupling networks was shorter than 2 meters in length.

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

b) For test applied to unshielded un-symmetrically operated interconnection lines of EUT:

The surge was applied to the lines via the capacitive coupling. The coupling / decoupling networks didn't influence the specified functional conditions of the EUT. The interconnection line between the EUT and the coupling/decoupling networks was shorter than 2 meters in length.

c) For test applied to unshielded symmetrically operated interconnection / telecommunication lines of EUT:

The surge was applied to the lines via gas arrestors coupling. Test levels below the ignition point of the coupling arrestor were not specified. The interconnection line between the EUT and the coupling/decoupling networks was shorter than 2 meters in length.

8.6.4. TEST SETUP



- For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.

8.6.5. TEST RESULTS

Temperature	18°C	**Humidity**	58% RH
Pressure	1008mbar	**Tested By**	David Cheng
Required Passing Performance		**Criterion B**	

Test Point	Polarity	Test Level (KV)	Performance Criterion	Observation	Result
L – N	+/-	1	☒A ☐B	**Note** ☒1 ☐2	PASS

NOTE: *1. There was no change compared with initial operation during the test.*

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

8.7. CONDUCTED RADIO FREQUENCY DISTURBANCES (CS)

8.7.1. TEST SPECIFICATION

Basic Standard:	EN 61000-4-6
Frequency Range:	0.15 MHz ~ 80 MHz
Field Strength:	3 Vrms
Modulation:	1kHz Sine Wave, 80%, AM Modulation
Frequency Step:	1 % of preceding frequency value
Coupled cable:	Power Mains, Unshielded
Coupling device:	CDN-M2 (2 wires)

8.7.2. TEST INSTRUMENT

CS Room				
Name of Equipment	**Manufacturer**	**Model**	**Serial Number**	**Calibration Due**
RF Generator	Schaffner	NSG 2070-1	1061	07/30/2009
CDN	Schaffner	CDN M316	19600	07/30/2009
CDN	Schaffner	CDN M216	19294	07/30/2009
EM Clamp	Schaffner	KEMZ 801	19227	03/03/2010
CDN	Schaffner	CDN T002	15881	01/07/2010
CDN	Teseq	CDN T400A	25674	01/07/2010
CDN	Teseq	CDN T800	26155	01/07/2010
Attenuator	Schaffner	INA2070-1	2061	No Calibration Required
Software	Win2070.exe			

NOTE: *1. The calibration interval of the above test instruments is 12 months and the calibrations are traceable to NML/ROC and NIST/USA.*
2. N.C.R.= No Calibration required

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

8.7.3. TEST PROCEDURE (please refer to measurement standard or CCS SOP PA-026)

The EUT shall be tested within its intended operating and climatic conditions.

The test shell performed with the test generator connected to each of the coupling and decoupling devices in turn, while the other non-excited RF input ports of the coupling devices are terminated by a 50-ohm load resistor.

The frequency range was swept from 150 kHz to 80 MHz, using the signal level established during the setting process and with a disturbance signal of 80 % amplitude. The signal was modulated with a 1 kHz sine wave, pausing to adjust the RF signal level or the switch coupling devices as necessary. The sweep rate was 1.5×10^{-3} decades/s. Where the frequency range is swept incrementally, the step size was 1 % of preceding frequency value from 150 kHz to 80 MHz.

The dwell time at each frequency was less than the time necessary for the EUT to be exercised, and able to respond. Sensitive frequencies such as clock frequency(ies) and harmonics or frequencies of dominant interest, was analyzed separately.

Attempts was made to fully exercise the EUT during testing, and to fully interrogate all exercise modes selected for susceptibility.

8.7.4. TEST SETUP



Note: *1. The EUT is setup 0.1m above Ground Reference Plane*
2. The CDNs and / or EM clamp used for real test depends on ports and cables configuration of EUT.

- For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.

NOTE:

TABLE-TOP AND FLOOR-STANDING EQUIPMENT

The equipment to be tested is placed on an insulating support of 0.1 meters height above a ground reference plane. All relevant cables shall be provided with the appropriate coupling and decoupling devices at a distance between 0.1 meters and 0.3 meters from the projected geometry of the EUT on the ground reference plane.

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

8.7.5. TEST RESULTS

Temperature	18°C	**Humidity**	58% RH
Pressure	1008mbar	**Tested By**	David Cheng
Required Passing Performance		**Criterion A**	

Frequency Band (MHz)	Field Strength (Vrms)	Cable	Injection Method	Performance Criterion	Observation	Result
0.15 ~ 80	3	AC Power Line (0.3m)	CDN-M2	☒**A** ☐**B**	**Note** ☒**1** ☐**2**	PASS

NOTE: *1. There was no change compared with initial operation during the test.*

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

8.8. POWER FREQUENCY MAGNETIC FIELD

8.8.1. TEST SPECIFICATION

Basic Standard:	EN 61000-4-8
Frequency Range:	50Hz
Field Strength:	1 A/m
Observation Time:	1 minute
Inductance Coil:	Rectangular type, 1mx1m

8.8.2. TEST INSTRUMENT

Immunity Shield Room				
Name of Equipment	**Manufacturer**	**Model**	**Serial Number**	**Calibration Due**
Induction Coil Interface	Schaffner	INA 21141	6009	No Calibration Required
5KVA AC Power Source	Schaffner	NSG 1007	55131	No Calibration Required
TRMS Clamp Meter	CHY	932C	995000273	06/14/2010
Magnetic Field Meter	Sypris	4080	0247	03/11/2010

NOTE: *1. The calibration interval of the above test instruments is 12 months and the calibrations are traceable to NML/ROC and NIST/USA.*
2. N.C.R.= No Calibration required

8.8.3. TEST PROCEDURE (please refer to measurement standard or CCS SOP PA-027)

a. The equipment is configured and connected to satisfy its functional requirements. It shall be placed on the GRP with the interposition of a 0.1m-thick insulating support.

b. The equipment cabinets shall be connected to the safety earth directly on the GRP via the earth terminal of the EUT.

c. The power supply, input and output circuits shall be connected to the sources of power supply, control and signal.

d. The cables supplied or recommended by the equipment manufacturer shall be used. 1 meter of all cables used shall be exposed to the magnetic field.

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

8.8.4. TEST SETUP



- For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.

NOTE:
TABLETOP EQUIPMENT
The equipment shall be subjected to the test magnetic field by using the induction coil of standard dimension (1 m x 1 m). The induction coil shall then be rotated by 90 degrees in order to expose the EUT to the test field with different orientations.

FLOOR-STANDING EQUIPMENT
The equipment shall be subjected to the test magnetic field by using induction coils of suitable dimensions. The test shall be repeated by moving and shifting the induction coils, in order to test the whole volume of the EUT for each orthogonal direction. The test shall be repeated with the coil shifted to different positions along the side of the EUT, in steps corresponding to 50 % of the shortest side of the coil. The induction coil shall then be rotated by 90 degrees in order to expose the EUT to the test field with different orientations.

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

8.8.5. TEST RESULTS

Temperature	N/A	**Humidity**	N/A
Pressure	N/A	**Tested By**	N/A
Required Passing Performance		**Criterion A**	

DIRECTION	Field Strength (A/m)	Performance Criterion	OBSERVATION	RESULTS
X	1	A	Note	N/A
Y	1	A	Note	N/A
Z	1	A	Note	N/A

NOTE: *The EUT is not containing any component that is susceptible to a 50 Hz or 60 Hz magnetic field. Therefore, this requirement is not applicable to the EUT.*

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

8.9. VOLTAGE DIP & VOLTAGE INTERRUPTIONS

8.9.1. TEST SPECIFICATION

Basic Standard:	EN 61000-4-11
Test duration time:	Minimum three test events in sequence
Interval between event:	Minimum 10 seconds
Phase Angle:	0^o / 45^o / 90^o / 135^o / 180^o / 225^o / 270^o / 315^o / 360^o
Test cycle:	3 times

8.9.2. TEST INSTRUMENT

Immunity shielded room				
Name of Equipment	**Manufacturer**	**Model**	**Serial Number**	**Calibration Due**
Dips/Interruption/Variations Tester	Schaffner	BEST EMC V2.3	200031A024SC	11/09/2009
Software	WinBest.exe			

NOTE: *1. The calibration interval of the above test instruments is 12 months and the calibrations are traceable to NML/ROC and NIST/USA.*
2. N.C.R.= No Calibration required

8.9.3. TEST PROCEDURE (please refer to measurement standard or CCS SOP PA-028)

1. The EUT and support units were located on a wooden table, 0.8 m away from ground floor.
2. Setting the parameter of tests and then perform the test software of test simulator.
3. Conditions changes to occur at 0 degree crossover point of the voltage waveform.
4. Recording the test result in test record form.

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

8.9.4. TEST SETUP



- For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.

8.9.5. TEST RESULTS

Temperature	18°C	**Humidity**	58% RH
Pressure	1008mbar	**Tested By**	David Cheng
Required Passing Performance	**Criterion B: >95% reduction 0.5 period** **Criterion C: 30% reduction 25 period & >95% reduction 250 period**		

Test Power: 230Vac, 50Hz				
Voltage (% Reduction)	**Duration (Period)**	**Performance Criterion**	**Observation**	**Test Result**
>95	0.5	☒**A** ☐**B** ☐**C**	**Note** ☒**1** ☐**2**	PASS
30	25	☒**A** ☐**B** ☐**C**	**Note** ☒**1** ☐**2**	PASS
>95	250	☐**A** ☒**B** ☐**C**	**Note** ☐**1** ☒**2**	PASS

NOTE: *1. There was no change compared with initial operation during and after the test. No unintentional response was found during the test.*

2. EUT shut down, but it could recover automatically afterwards.

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

9 PHOTOGRAPHS OF THE TEST CONFIGURATION

CONDUCTED EMISSION TEST

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

RADIATED EMISSION TEST

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

Harmonic & Flick Test

ESD Test

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

RS Test

EFT Test



This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

Surge Test

CS Test

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.

Voltage Dip Test

This report shall not be reproduced except in full, without the written approval of Compliance Certification Services.